



ऑयल एन्ड नेचुरल गैस कारपोरेशन लिमिटेड
OIL AND NATURAL GAS CORPORATION LTD
अग्निशमन सेवार्यै, अहमदाबाद परिसम्पत्ति
FIRE SERVICES : AHMEDABAD ASSET
अवनि भवन, भूतल, चांदखेडा, अहमदाबाद
AVANI BHAVAN, GROUND FLOOR
CHANDKHEDA, AHMEDABAD

Fire Safety Arrangement at KV ONGC Chandkheda

This is to certify that existing fire safety arrangement at Kendriya Vidyalaya, ONGC Chandkheda, Ahmedabad is adequate. Deployment of Portable fire extinguishers has also been reviewed recently on 25.07.2022 and quantity of the fire extinguishers has been increased (Water type 9 ltrs -20 nos, DCP ABC Type 4/6 kg - 03 nos, CO2 type 2 Kg-09 Nos, Total-32 nos). These are checked quarterly and Fire fighting training/drills are conducted time to time by Fire Services Department of ONGC Ahmedabad for taking prompt and appropriate action by School staff in case of an fire incident.

(S K Rai)

GM (FS) - I/c Fire Services

संजय कुमार राय
प्रभादी अग्निशमन सेवार्यै
ऑयलजीसी, अहमदाबाद परिसम्पत्ति